

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED

Permit #: PRRES20243620
Address: 3216 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

| | | | |
|-----------------|------------------|--------------------|--------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Erosion Control | Mitchell Schwarz | Failed - Stop Work | Tuesday, August 13, 2024 |

Corrective Action Required

| | | |
|---|------------------------------------|--|
| 1 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. |
|---|------------------------------------|--|

STOP WORK ISSUED, footing poured without erosion control
No address

Comments: