

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241619
Address: 1805 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Tuesday, August 13, 2024

Informational:
1 Misc 8-6-24 Dustin A, Dw is framed and compacted to city specs. Curb was missing a chunk. Enough that it needed to be replaced. Contractor cut out Curb that was damaged (seam to seam) and meets pre pour specs. Approved to pour

8-13-24 Dustin A, DW is poured to city specs. Passed

Comments: