



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114582, Building Permit - Commercial
Address: 828 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Failed	Wednesday, September 28, 2011

Corrective Action Required
1 MISC

G.E.C. NOT CONNECTED TO GROUND ROD

Final Electrical Inspection - Commercial	John Borns	Not Ready	Wednesday, September 28, 2011
---	------------	-----------	-------------------------------

Comments: