

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Ready for Temp CO	Wednesday, July 31, 2024

Corrective Action Required:

1	Miscellaneous Correction	Both units: plot has not had it's final grading for plot plan inspection Sod, splash pads and sump pump extensions are not complete
		Both properties passed for TCO only
		Pay TCO Fee

Comments: