



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114294, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:160, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Thursday, September 29, 2011

Partial Correction
1 MISC

WALL FRAMING APPROVED. NO ELECTRICAL SHEETS IN PERMIT
PRINT SET, SO ELECTRICAL WIRING NOT READY FOR
INSPECTION -- NOT OK TO COVER

Comments: