

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233168
Address: 2130 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, August 14, 2024

Corrective Action Required:

1	Misc	- Restore erosion control at front of house - Lower water meter in pit to 14"-18" from lid (too high now) - Final grading and sod - Provide splash pads to divert water 36" away from foundation
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	- Restore erosion control at front of house - Lower water meter in pit to 14"-18" from lid (too high now) - Final grading and sod - Provide splash pads to divert water 36" away from foundation
---	--------------------------	---

Builder submitted a TCO extension and was excepted by the City

Comments: