

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20241662  
Address: 1200 SW LONGVIEW PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Devon Perry	Partial	Wednesday, August 14, 2024

Informational:	
1 Misc	8-14-24 Water sample on 8-6 which failed Had them re do the water testing process and pulled samples number 1 on 8-13 which passed and pulled water samples number 2 on 8-14-24

**Comments:**