

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236429  
Address: 2210 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Wednesday, August 14, 2024

Corrective Action Required:

1	Miscellaneous Correction	2210 NW Killarney. Occupancy
		-Install security screws in hinges at walkout basement exterior door
		-Secure water sprinkler control valve in basement
		Sod and exterior splash pads are not installed

**Comments:**