

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242853
Address: 1901 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|---------------------------|
| All Rough Inspection - Residential | Alex Fischer | Failed | Thursday, August 08, 2024 |

Informational:

| | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | Garage portal inspection passed and is okay to cover. |
|---|--------------------------|---|

This is a partial pass only

Corrective Action Required:

| | | |
|---|------|---|
| 2 | Misc | -Missing 2ea TJC-37 truss brackets (west side of garage) -Missing fire blocking at top plate in basement bedroom closet (east) |
|---|------|---|

Comments: