

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240725
Address: 2219 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, August 15, 2024

Corrective Action Required:

1 Misc

- provide proper slope for all dwv in attic space
- address over notched valley rafter above master
- solid blocking all sheathing breaks
- strap top plate where lapped less than 24" left of fireplace
- basement plans do not match city stamped plans(missing all details)
- basement not inspected.

Comments: