

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240626  
Address: 3212 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Thursday, August 15, 2024

Corrective Action Required:

1	Misc	-Final grade and sod -Splash blocks and sump pump discharge to extend 36" from foundation -uncover covered water meter -obtain issued irrigation permit
---	------	--

**Comments:**