



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115260, Building Permit - Commercial
Address: 210 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Plumbing Inspection - Commercial	John Borns	Passed	Thursday, September 29, 2011

Comments: SUMP PUMP DISCHARGE REMOVED FROM SANITARY DRAIN SYSTEM AND RE-PIPED TO DISCHARGE AT PARKING LOT OUTSIDE BUILDING SOUTH WALL.