

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240530
Address: 2528 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, August 15, 2024

Corrective Action Required:

1	Misc	Water supply lines to jacuzzi tub in master suite bathroom not installed.
---	------	---

****You need to move the pump receptacle to within direct view and within 12" of the access opening. Access for service must be unobstructed opening**

****OK TO INSULATE**

Comments: