



Existing 6"
Double check
backflow
preventer

Tie onto
existing 6"
water line at
exterior of vault.

Sanitary
sewer
main

Legend

- 6" Water main
- Water service
- 6" sewer main
- Fire hydrant
- Isolation valve
- Backflow vault

Open trench
replace
approximately
860' of 6" ductile
iron water line
with 6" C-900
including 23 1" &
3/4" taps & two
2" taps.

Bore and
replace
approximat
ely 300' if
6" ductile
iron water
line with 6"
HDPE.