

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232726
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Devon Perry	Passed	Thursday, August 15, 2024

Informational:

1	Misc	8-15-24 DP. AJ's crew with ESS was onsite and completed a hydrostatic test on the public 12" water main, line A and line B south phase. This was the entire line from the tie in point on Colburn road around to just passed the backflow vault along Lee's Summit RD. The pressure held at 175 psi for 2 hours and passed.
---	------	---

Comments: