

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------------|----------|---------------------------|
| Erosion Sediment Control (ESC) Inspection | Patrick Schonfeldt | Failed | Thursday, August 15, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | 8-15-24 PS Discussed erosion control with Brandon GC, overgrown vegetation addressed, lots have been hydro seeded, erosion control is being addressed within the next 2 business days for silt fence along 150 side and arboridge side. Silt fence required as grade is sloped towards sidewalk until vegetation is established. Sidewalk will be cleaned with silt fence install |
|---|------|---|

Comments: