

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242428
Address: 3116 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Friday, August 16, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Exterior garage portal sheeting needs to extend to both top plates to tie in -Back patio framing passed, but can not be covered until electrical has been installed and passed
---	--------------------------	--

Comments: