



July 25, 2024

Pat Cochran Concrete

Re: 2771 SW 11<sup>th</sup> Terrace  
Lot 167 Highland Meadows  
Lee's Summit Permit: PRRES20240886

Apex Engineers, Inc. observed the preparation for the suspended stoop slab at the above-referenced address.

The stoop slab will be suspended. The forms and reinforcing steel were found to be clean, well-aligned, properly supported, and in general compliance with the approved design.

Note:

- The inspection was performed at 4:30 pm.
- At the time of the inspection the temperature was 92° F.
- Erosion control was in place at the time of our firm's site visit.
- Stoop flashing had been placed.

Our firm recommends approval of the suspended stoop slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

---

#### LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,  
Apex Engineers, Inc.

  
Stephen Fitch  
Inspections Manager

Clayton J. Hess, P.E.  
Principal

