

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233918  
Address: 2234 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Friday, August 16, 2024

Corrective Action Required:

1	Misc	-Complete splash blocks, foundation drainage -Loose receptacle left of range -Secure handrail at top flight of basement stairs -Install ladder in window well greater than 44" in height
---	------	---

**Comments:**