

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20236289
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Ready for Temp CO	Friday, August 16, 2024

Corrective Action Required:

1	Misc	- provide back flow preventer to supply of ice maker ASSE 1024 leave ice maker disconnected until inspection - Approval of FD
---	------	--

*** OK for TCO

Comments: