

DEVELOPMENT SERVICES

Building Permit - Commercial Project Title: MCC AUTOMOTIVE INSTITUTE - BUILDING ADDITION Work Desc: ADDITION COMMERCIAL	Permit No: PRCOM20240778 Date Issued: August 19, 2024
--	--

Project Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081 Legal Description: SEC-9 TWP-47 RNG-32 --- PT NE 1/4 DAF: BEG NE COR SD 1/4 TH W ALG N LI SEC 9 2094.87' TH S 03 DEG 15 SEC E 391.38' TH S 88 DEG 13 MIN 46 SEC E 1486.29' TH N 3 DEG 23 MIN 20 SEC E 322' S 87 DEG 50 MIN 3 09 MIN 27 SEC E 310.25' TH N 87 DEG 41 MIN 21 SEC E 409.48' TH S 2 DEG 19 MIN 21 SEC W 47.69' N 87 D Parcel No: 63600010402300000 County: JACKSON	Permit Holder: MCCOWN GORDON CONSTRUCTION LLC 850 MAIN ST KANSAS CITY, MO 64105
---	---

Activities Included for this Project: zAddition Commercial, License Tax, License Tax Credit, Alarm Permit, Sprinkler Permit, Fire Rated Assemblies Permit, Water, Sanitary Sewer, Paved Surface, Storm Sewer, Site Grading,

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITTED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS. NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Fire Plan Review

2 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Verified at inspection.Ensure the building address/Identifier is visible on the new facade.

4 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

The design professional shall ensure the correct size and distribution of fire extinguishers..

Building Plan Review

4 Prior to the installation or construction of any elevator equipment, an elevator equipment permit shall be obtained from the Missouri Department of Public Safety or its authorized representative.

Action required: Comment is informational.
4/8/24 - acknowledged in letter.

5 Prior to the operation of any new elevator equipment or the issuance of the operating certificate, such elevator equipment shall be inspected by a licensed inspector. Testing must be performed in accordance with these rules and regulations. The testing must be witnessed by a licensed inspector.

Action required: Comment is informational.
4/8/24 - acknowledged in letter.

6 Elevator Safety Act and Rules 701.361 - Each privately owned or operated installation and each installation owned or operated by the state of Missouri or any political subdivision of the state shall have a certificate of inspection and meet the safety code promulgated pursuant to sections 701.350 to 701.380.

Action required: Comment is informational.
4/8/24 - acknowledged in letter.

Licensed Contractors

Signature of	
Applicant: _____	Date: _____
Print name: _____	Company Name: _____