

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed - Stop Work	Monday, August 19, 2024

Informational

1	Miscellaneous Correction	Erosion control is torn down, damaged or missing along the properties west side. Erosion control is missing along the properties front east side
---	--------------------------	--

Full erosion control measures must be maintained until CoFo

Informational

2	Miscellaneous Correction	Erosion control is in place and must be maintained until CoFo
---	--------------------------	---

Corrective Action Required

3	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	-------------------------	--

All silt needs to be cleaned off of approach and sidewalks

8-19-24 Dustin A SW's and ADA ramp still has silt and dirt on it.

Comments: