

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20233869  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit</b>	Shannon McGuire	Failed	Friday, August 16, 2024

Corrective Action Required:

1

The required ground cover was not installed at the time of inspection. Please install the required ground cover as depicted on the approved PDP.

Corrective Action Required:

2

A total of 8 ADA stalls are required. No new ADA stalls were provided with this parking lot expansion. Many of the existing ADA stalls are not ADA compliant as they are not adjacent to the required hatched aisle. Currently there are only 6 ADA compliant parking stalls to serve the existing and new parking lot. This can be rectified by striping off the 3rd parking stall near the gym entrance. Please contact me should you need clarification.

Corrective Action Required:

3

Many of the ADA stalls do not have the required signage at the head of the stall. Please install the required signage.

**Comments:**