

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236080
Address: 2354 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, August 19, 2024

Corrective Action Required:

1	Misc	-will check gb bracing when completed -fire block garage wall into furr down -address holes drilled closer than 2" to one another and over bored in joists above garage -rear kitchen windows not framed to cspf specifications -address rear hearth room wall not built to plans -address holes bored closer than 2" to the bottom of the floor joists and each other above hearth room -fireblock foyer closet into furr down -ensure dryer vent length does not exceed 35' -stair well wall to be framed to plans
---	------	--

Comments: