

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240055  
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Curb - Proof Roll</b>	Devon Perry	Partial	Tuesday, August 20, 2024

Informational:

1 Misc

7-10-24 DP. I sent Dustin out to meet Reike onsite. They proof rolled the aggregate on the curb lines on the north and east sides. Everything was very tight and passed.

8-15-24 DP. I met Rieke onsite today for a proof roll for the road leading down to the east side of the property. They are currently rolling it out and will try again tomorrow.

8-16-24 DP. Proof roll passed

**Comments:**