

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Tuesday, August 20, 2024

Corrective Action Required:

1	FIRST FLOOR	*****AREAS APPROVED TO COVER: Additon complete except as noted: *AHU -Address duct penetration/ complete firewall
---	-------------	--

\*\*Existing side:  
1E-314-seal penetrations  
300C-seal penetrations and label firewall  
1E-315-Label firewall  
1E-313-seal penetrations and label firewall

Corrective Action Required:

2	SECOND FLOOR	Above-ceiling OK below: -Soffits in waiting room area and adjacent corridors **Complete except as noted below: -Team Center 2E-330, Staff Lounge 2E-232, Staff TLT 2E-231A, Elevator Lobby
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	*****AREAS APPROVED TO COVER: Soffits at 3E-355, 346, 338, 241, 244, 306
---	-------------	---

**Comments:**

