

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241832
Address: 2131 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, August 20, 2024

Corrective Action Required:
2 Misc

- 4 full height 2x6 studs a each side of front door
- fire block at dryer vent into ceiling space
- seal top plate penetrations right of front door
- sister notched exterior studs in basement
- address holes drilled closer than 2" to one another
- secure electrical to code in furr down
- missing but for anchor bolt at rec room rear opening window
- missing stud pac at SE bed 3
- fire block plumbing chase into furr down bed 4 closet

Comments: