

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240725
Address: 2219 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, August 20, 2024

Corrective Action Required:

1 Misc

- address over notched valley rafter above master
- fireblock vertically, horizontally every 10' (when using Unfaced insulation in t must be packed tightly and securely)
- secure all electrical in furr down
- seal top plate penetration W bed 3 wall
- address wall space to furr down fire blocking throughout basement, (when using Unfaced insulation in t must be packed tightly and securely)
-

Comments: