

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236029

Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
829 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Failed	Tuesday, August 20, 2024

Corrective Action Required:

1	Misc	-Complete underground gas line to middle unit
---	------	---

*pressure test for interior gas line OK

Comments: