

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242469
Address: 1609 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|--------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Tuesday, August 20, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Garage portal frame nailing okay -trusses for front porch okay to cover -engineered bracing at front porch/NE Corner of home not correct |
|---|------|---|

Not a complete inspection only portal and porch

Comments: