

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, August 20, 2024

Corrective Action Required:

1	Misc	Main floor-OK to cover: -Roof-ceiling assembly only
---	------	--

Corrective Action Required:

2	FIRST FLOOR	-Provide new revised plan -Fire stop wall plate penetrations -Hangers at lvl connections near stair -Install restroom grab bar blockings -Submit roof truss repair for trusses above pool equipment room and floor trusses above golf simulator room -Complete all electrical
---	-------------	--

**Not a complete list

Comments: