

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233918
Address: 2234 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Wednesday, August 21, 2024

Corrective Action Required:

1	Misc	-Re inspection fee assessed. Fees must be paid before occupancy is issued -Loose receptacle left of range-NOT DONE **Corrections from failed plot plan inspection- -Correct negative slope at landscaping at front corner of house -Uncover water meter
---	------	---

Comments: