

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Wednesday, August 21, 2024

Corrective Action Required:

1	Misc	-Install ceiling lights -Support furnace PVC pipe every 5 ft; plumbing vent every 4 ft -Complete mechanical duct to ceiling register -Complete sprinkler head installation
---	------	---

Comments: