

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242482  
Address: 3391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - R</b>	Shawn Hoffman	Failed	Wednesday, August 21, 2024

Corrective Action Required:

1 Misc

- ALL WAS COVERED AT TIME OF INSPECTION
- SUPPLIED PICTURES SHOWS A NON APPROVED CONNECTION TO SEWER MAIN. ( DIG UT AND REPAIR )
- MINIMUM OF 16" OF PIPE REQUIRED BEWTEEN 45'S
- 

\*\*\* open ground to verify condition to main

Comments: