

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Robb Popp	Failed	Wednesday, August 21, 2024

Informational:	
1 Misc	*(13) of (13) piers for light pole bases in North parking lot addition
Corrective Action Required:	
2 Miscellaneous	*(2) piers for light poles at new North addition lot
Correction	-Piers to be min 5' below grade per detail. -Support rebar min 3" from earth

Comments: