

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, August 21, 2024

Corrective Action Required:

1	Misc	**Footing at south side was already poured without city inspection. Shall submit engineer report to city
---	------	--

Informational:

2	Misc	Exterior wall footing OK: -1/B to 1/F to F/13
---	------	--

Informational:

3	Misc	Engineer inspection report submitted for partial north and west footing and north&east foundation wall
---	------	--

Comments: