

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	Devon Perry	Partial	Thursday, August 22, 2024

Informational:
1 Misc 8-21-24 DP. Floyd with She Digs It was onsite and started excavating and laying the 6" fire line. They Exposed the tie in point at STA 4+95.59 and laid 6" DIP with poly wrap up to STA 4+50. They had proper bedding under the new main.

Comments: