



Substantial Completion and Temporary Occupancy Extension Request

Permit Number	Date
PRRES20236052	8/22/24
Project Name	Project Address
OS 13	3710 SW Maryville Pl

Instructions: This form must be completed to request the extension of additional time on a project.

Reason for Delay:

Provide a brief description of why the remaining items of work were unable to be completed during the initial completion period.

Failed city inspection items :

PLOT PLAN

-Water meters in 3716 and 3712 appears to be below grade.

-Water meter for 3718 is covered

-Water valves in lot 3710 are about 24 inches above grade

OCCUPANCY

-Sump pump extension are not installed

-Sod and splash pads are not installed

-Plot plan must pass

All items are scheduled to be done in the next 2 weeks



LEE'S SUMMIT MISSOURI

Schedule for Completion:

Provide a brief schedule of expected completion dates for the remaining corrective actions not yet complete. Inspections may be viewed by visiting this link and inputting the permit number:

<https://devservices.cityofls.net/Permit/Locator>

All items on inspection are scheduled and will be completed in the next two weeks.

Name: Bruce Roach

Phone: 913-353-0655

E-Mail: permitting@summithomeskc.com

City Review:

This request will be reviewed by City Staff associated with this project to determine if the extension is warranted. If additional information or clarification is needed, staff will contact the person below to resolve these matters. Reviews are typically completed within two business days and if additional time is required the signee will be contacted with the timeframe for completion.

Approval (City Use): _____

Date: _____

Development Services

220 SE Green Street | Lee's Summit, MO 64063 | P: 816.969.1200 | F: 816.969.1221 | cityofLS.net