

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235728
Address: 3726 SW MARYVILLE PL, LEES SUMMIT, MO 640823728 SW MARYVILLE PL, LEES SUMMIT, MO
640823730 SW MARYVILLE PL, LEES SUMMIT, MO 640823722 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, August 22, 2024

Corrective Action Required:

2	Miscellaneous	3722
	Correction	Water meter is covered with sod
		3730
		Water meter extension ring is off set from the well
		3728
		Water valve is 18 inches above grade
		All other items have been corrected

Comments: