S LEE'S SUMMIT

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

August 22, 2024

HIGHTECH SIGNS OF MID-AMERICA LLC 2338 MERRIAM LANE KANSAS CITY, KS 66106 Karl Greer 2338 Merriam Lane Kansas City, KS 66106

PRSGN20244412 Permit No: Project Title: Attic Storage Project Address: 4104 NE Port Drive, lees summit MO 640544101 NE PORT DR, LEES SUMMIT, MO 64064 Parcel Number: 43600038800000000 Location / Legal LAKEWOOD BUSINESS PARK LOT 33A & LOTS 34-36---LOT 35 Description: Type of Work: SIGN Occupancy Group: NOT APPLICABLE Installation of 132.3 SQFT raceway mounted LED lit channel letters on west elevation, south Description: end of building

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Sign Permit Review

Reviewed By: Ian Trefren

. .

Rejected

Fire Department (816) 969-1300

1. (Sec. 9.200(H)(3)) - Visible raceways or conduits are not permitted on attached wall signs. Please revise design to incorporate electrical components behind the wall

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.