

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241108  
Address: 2520 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, August 22, 2024

Corrective Action Required:

1	Misc	-Equivalent nailing of rafters to wall top plates with 4-10d box nails
		-Provide 5-studs pack at lvl support near fireplace **Install strike plate to protect wiring
		**OK TO INSULATE

**Comments:**