

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240530  
Address: 2528 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, August 22, 2024

Corrective Action Required:

1	Misc	Water supply lines to jacuzzi tub in master suite bathroom not installed.
---	------	---

**\*\*You need to move the pump receptacle to within direct view and within 12" of the access opening. Access for service must be unobstructed opening**

**\*\*OK TO INSULATE**

**Comments:**