

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240001
Address: 2604 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, August 22, 2024

Corrective Action Required:

1	Misc	-Vent hose at powder room not installed **Protect fan duct from damage with min 16 gauge strike plates; flex duct is limited to max 14 ft run
---	------	---

**OK TO INSULATE

Comments: