

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242187
Address: 1613 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, August 22, 2024

Corrective Action Required:

1	Misc	-anchor bolts to be within 12" of plate breaks -fire block garage rear wall into ceiling space -seal all low voltage penetrations -missing multiple truss hangers throughout -nail trusses together to plans (missing nails) -address over notched floor joist near stairs for dwv -support hvac supply vents to code -use approved hangers for csst line -bond gas line
---	------	--

Comments: