

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242214
Address: 3816 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Devon Perry	Passed	Friday, August 23, 2024

Informational:

1 Misc

8-14-24 Dustin A, SW is formed and compacted to city specs. Slopes are in compliance. Approved to pour

8-23-24 DP. SW was poured, cross slopes are in compliance and forms have been removed. Passed.

Comments: