

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240886  
Address: 2771 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, August 23, 2024

Corrective Action Required:  
2 Misc

Fb= fire block/ draft

- Top plate of exterior wall near owners entrance and B- vent chase has less than 24" of over lap
- Fb top plate at oven electrical
- Address framing of exterior corner at bedroom 2 and entrance \*\*\* ( 3 studs minimum at exterior corners and top plate not tied in)

**Comments:**