

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240550

Address: 3736 SW KNOXVILLE CT, LEES SUMMIT, MO 640823734 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Friday, August 23, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Seal exterior penetrations - Sod, sump pump extensions and splash blocks are not installed - Plot plan not ready
---	--------------------------	--

Builder sent in a TCO extension form. This is the first extension request and builder is actively working on the exterior of the property.

Comments: