

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Friday, August 23, 2024

Informational:

1	Miscellaneous Correction	Sump pump extension is not installed -Sod and splash pads are not installed -Seal penetration in siding at gas line -Exterior grading has not been completed for a plot plan inspection -Plot plan must pass
---	--------------------------	--

This is the third TCO extension for this permit. Builder sent in another TCO extension form. A drive by inspection was done and this property has workers trying to finish up the exterior so an occupancy inspection can be called in.

Comments: