

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234499
Address: 2210 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, August 23, 2024

Corrective Action Required:

1 Misc

- final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- label all non GFCI outlets in unfinished spaces
- provide 3rd party documentation for suspended slab
- afci protection for circuits as required by code see (master washer, 2nd floor washer,x-mas,7 treadmill, etc.)
- provide as graded plot plan

Comments: