

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242151  
Address: 2127 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, August 23, 2024

Corrective Action Required:  
2 Misc

- fireblock rear garage wall to furr down ceiling space (see at owners entry)
- seal penetrations in return air stud space In bed 2
- fireblock wall space to ceiling space at entry coat closet
- missing nails in hanger above kitchen
- missing stud in basement bathroom
- all anchor bolts in basement to be tight
- fireblock bed 4 closet to ceiling space
- fireblock beam ends in basement

**Comments:**